

Annexure C  
PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

No. GRDW 05 / GOKAK / LAB / 2024 - 25 / 001 Date: 03/09/2024  
It is certified that an inspection team headed by..... Udaykumar P. Kamble.....

(Name of Officers with designation) from Assistant Executive Engineer, PHED

inspected the G.E.S. Navachetan School, Gokak.....

(Name & Address of the school) on 03/09/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. GRDW 05 / GOKAK / LAB dated 03/09/2024.....Of

GRDW 05 Taluka water quality Lab Gokak (PHED Lab) certified that the G.E.S. Navachetan School, Gokak.....

(name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State / U.T Govt.

This certificate is valid till :..... 1 Year.....

Signature with Seal :.....

Assistant Executive Engineer  
R.W.S. and S. Sub-Dn. Gokak

Name :.....

Udaykumar P. Kamble

Designation :.....

Assistant Executive Engineer

To

Principal.....

G.E.S. Navachetan School, Gokak

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Manager  
Gokak Education Society's  
GES Navachetan School, Gokak

Principal  
Gokak Education Society's  
GES Navachetan School, Gokak



**RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK**  
 District:Belagavi Laboratory Name:Gokak Taluka Lab

**TEST REPORT**

Name Of District: Belagavi  
 Name Of Taluka: Gokak  
 Name of School : GES Navachetan School Gokak

Report date: 02-09-2024  
 Report Number: 001  
 Reference: Sample receipt Form  
 Sample receipt date: 02-09-2024  
 Sample code:001  
 Date of Sample collection: 02-09-2024  
 Analysis start date: 02-09-2024  
 Analysis completion date: 02-09-2024  
 Sample collection protocol: IS 3025(Part-1)  
 Sample quantity: 1litre

Sample Particulars: Borewell

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
1.	pH Value @Temp25.0°C	7.64	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 1983
2.	Specific Conductance,µS/cm@Temp°C	160	-	-	IS 3025 (Part-14) : 1984
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):1983
5.	Colour, Hazen Units	5	5	15	IS 3025 (Part-4) :1983
6.	Turbidity, NTU	0.8	1	5	IS 3025 (Part-10) : 1984
7.	Total Dissolved Solids@ 105°C, mg/l	95.5	500	2000	IS 3025 (Part-16) : 1984
8.	Alkalinity as CaCO <sub>3</sub> , mg/l	20.0	200	600	IS 3025 (Part-23) : 1986
9.	Total Hardness as CaCO <sub>3</sub> , mg/l	32.02	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	7.12	75	200	IS 3025 (Part-40) : 1991
11.	Magnesium as Mg, mg/l	2.84	30	100	IS 3025 (Part-46) : 1994
12.	Chloride as Cl, mg/l	11.50	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO <sub>4</sub> , mg/l	8.01	200	400	IS 3025 (Part-24) : 1986
14.	Fluoride as F, mg/l	0.08	1	1.5	APHA 23 <sup>rd</sup> Edition
15.	Nitrate as NO <sub>3</sub> , mg/l	4.21	45	No relaxation	APHA 23 <sup>rd</sup> Edition
16.	Iron as Fe, mg/l	0.06	1	No relaxation	IS 3025 (Part-53) : 2003

Remarks: The above tested parameters are within the Acceptable limits as per specification of IS 10500:2021.

Analysed by:  
  
 Analyst

Verified By:  
  
 Assistant Executive Engineer  
 R.W.S. and S. Sub-Div. Gokak.  
 RDWSD/WQMSP/TE/R/01

**Note:**

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

Manager  
 Gokak Education Society's  
 GES Navachetan School, Gokak

Principal  
 Gokak Education Society's  
 GES Navachetan School, Gokak